



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA181121

Certificate Holder: ShenZhen Lux Power Technology Co., Ltd
Room 403, 4th Floor, Building 63,
Zhongwu New Industrial Park,
Zhongwu Community, Hangcheng Street,
Baoan District,
Shenzhen
P.R. China

Class Description: Non-Declared
Product Description: Hybrid Inverter
Brand Name: LUXPOWERTek
Model No.: LXP-3K Hybrid
Markings: Input: 550Vdc Max, MPP voltage range 120-500Vdc
2x10A, IscPV 2x12.5A
Grid : 230V~ 50Hz, 15A Max, 3000VA
Battery: 40-60Vdc, charge/discharge current 66/66A,
charge/discharge power 3600/3600W
EPS output: 230V~ 50/60Hz 13A 3000VA
Class I, IP65

Standard: IEC 62109-1 Ed. 1.0
IEC 62109-2 Ed. 1.0
AS/NZS 4777.2:2015
IEC 62040-1 Ed. 1.0

Conditions: Nil

Certification Mark: SAA181121 or RCM

Date First Registered: 8 May 2018
Date of Expiry: 8 May 2023


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 08-05-18 181121/1